



MiniGrid Plate Switches (Modular)



The Click MODE range has recently been expanded to include a range of anthracite grey finished accessories to comply with current Building Regulations Part M.

Part M switches are developed largely as a modular range based on the large selection of switch modules available in the CLICK MINIGRID Module range. Simple, single screw fixing of modules offers the simplest possible means of installing and replacing modules.

MiniGrid Modular Plate Switches (Unfurnished)

Product Range

MiniGrid Modular Plate Switches (Unfurnished)

CMA401AG	1 Gang Plate Single Aperture
CMA402AG	1 Gang Plate Twin Aperture
CMA403AG	1 Gang Plate Triple Aperture
CMA404AG	2 Gang Plate (2+2) Aperture
CMA426AG	2 Gang Plate 6 In-Line Aperture



CMA401AG



CMA402AG



CMA403AG




CMA404AG



CMA426AG

MiniGrid Modular Plate Switches (Unfurnished)

Product Dimensional Drawings (mm)



MiniGrid Modular Plate Switches (Unfurnished)

Product Range

MiniGrid Modular Plate Switches (Unfurnished)

CMA512AG	12 MiniGrid Module Plate
CMA518AG	18 MiniGrid Module Plate
GR100**	6 MiniGrid Module Yoke
WA512	2 Gang Double Row K/O Box 47mm Deep
WA518	2 Gang Triple Row K/O Box 47mm Deep




CMA512AG



GR100PW



WA512






CMA518AG



WA518

MiniGrid Modular Plate Switches (Unfurnished)

Product Dimensional Drawings (mm)



Errors & Omissions excluded. Specification is subject to change without notice.

V1.0

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454

E-mail: sales@scolmore.com, technical@scolmore.com

Facsimile: 01827 63362

Website: www.scolmore.com

MiniGrid Modular Plate Switches (Unfurnished)

Technical Specification

MiniGrid Multi-Tier Modular Plate Switches (Unfurnished)

Material Composition	Front Plate: Urea GR100 Mounting Yoke: Galvanised Steel & Urea Back Boxes: Galvanised Steel
Cable Size	Dependent on modules fitted
Back Box Depth	Dependent on modules fitted
Modular	Yes
Warranty	20 Years
Anti Microbial Certified	Yes
LRV Value	8.9
IP Rating	IP20
Operational Temperature	-5° to +40°C
Standards	BS 5733 : 2010 + A1 : 2014 Modified ISO 22196

Additional Information

Ensure that the mains supply is isolated before commencing installation and refer to the circuit diagram with the relevant product.

Bare earth cables must always be covered with appropriate sleeving and wired to the earth terminal.

All white moulded accessories are manufactured using Urea Formaldehyde, which has similar inherent properties to antimicrobial additives that inhibit the growth of infectious diseases. All products were independently tested and achieved a 99.9% kill rate across all four types of the strains of bacteria - MRSA, E-Coli, Salmonella, and Klebsiella Pneumoniae.

CMA512AG requires (2x) GR100 MiniGrid Module Yokes. These plates are designed to be used with specified backbox WA512.

CMA518AG requires (3x) GR100 MiniGrid Module Yokes. These plates are designed to be used with specified backbox WA518.

Interchangeable with modules in the MINIGRID system



Part M Range

DECLARATION OF CONFORMITY

1. *Issuer Name* Scolmore International Limited
2. *Issuer Address* 1 Scolmore Park, Landsberg,
Lichfield Road Industrial Estate,
Tamworth, Staffordshire, B79 7XB
3. *Object(s) of Declaration* Part M Range
 - a. *Group* Modular Switch Plates (Unfurnished)
 - b. *Model No.* CMA401AG, CMA402AG, CMA403AG, CMA404AG, CMA426AG,
CMA512AG. CMA518AG
4. *The object of the declaration described above is in conformity with the requirements of the following Legislations:*
5. *All products contained within the aforementioned comply with the relevant standards and requirements listed below.*

BS 5733 : 2010 + A1 : 2014

6. *I hereby declare that the equipment named above has been designed to comply with the relevant sections of the above referenced specifications. The unit complies with all applicable Essential Requirements of the Directives.*

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001:2008

Signed, for and on behalf of: Scolmore International Limited



Steven Bettson BSc - Senior Technical Support Engineer

CE 15